

Number : C-19-0251-R01
Client : EKA PANO ve KABİN SİSTEMLERİ SAN. ve TİC.
LTD.ŞTİ.
Manufacturer : EKA PANO ve KABİN SİSTEMLERİ SAN. ve TİC.
LTD.ŞTİ.
Definition of the Samples : LOW VOLTAGE DISTRIBUTION PANEL with 5000 A
INPUT SWITCH
Technical Data : 60kA / 300 ms
Test Standard : IEC TR 61641:2014
Subject : TEST RESULT (PASSED)
Test Application : Test Under Conditions of Arcing Due to Internal Fault
Test Report Number : 19-0251-R01-N01-01
Test Report Date : 15.04.2020
Certificate Date : 14.10.2019

Person in Charge of Test

Cem AKDOĞAN



Head of Testing Laboratory

Cahit GÖKSEL



Sertifika detaylarını karekod ile kontrol edebilirsiniz.
You can check the certificate details via QR code.



www.lvt.com.tr